

Max. seal size	<ul style="list-style-type: none"> ■ Wall: 2200 x 1100 mm ■ Ceiling: 1000 mm width x ∞ length 										
Suitable subsoils	<ul style="list-style-type: none"> ■ Solid walls ≥ 100 mm 			<ul style="list-style-type: none"> ■ Drywall partitions ≥ 94 mm 				<ul style="list-style-type: none"> ■ Solid ceilings ≥ 150 mm 			
Suitable insulations	<ul style="list-style-type: none"> ■ Synthetic rubber with 11 up to max. 41,5 mm insulation thickness ■ Mineral fibre or stone wool with 20 up to max. 60 mm insulation thickness 										
Suitable installations	<ul style="list-style-type: none"> ■ Electric installation pipes made of PVC or polyolefin with max. single diameter 63 mm or bundles from max. 125 mm diameter ■ Copper pipes up to max. Ø 88,9 mm ■ Metal pipes up to max. Ø 160 mm ■ PE, PP and PVC up to max. Ø 160 mm 										

Dimensions of the AWM II collar

Collar dimensions (mm)	32	40	50	63	75	90	110	125	140	160	
Pipe's inner diameter (mm)	36	44	54	67	79	94	114	129	144	165	
Pipe's outer diameter (mm)	50	58	68	94	106	132	155	172	200	220	
Component height (mm)	26	26	26	26	26	26,6	26,6	40	40	40	
No. of fixing tabs (pcs)	2	2	2	4	4	4	4	4	6	6	